



性能规范		
阀门公称压力	1.6	MPa
阀后压力	0.3	
流量系数Kv	11	
工作温度	≤ 11℃	

技术要求

1. 装配前, 应将零件去除毛刺, 清洗干净, 装配后, 阀门应转动灵活, 无卡阻现象
2. 阀门的压力试验按GB/T 13927-1992《阀门的试验与检验》

26		温度杆	1				
25		毛细管	1				
24	ZZYP-16B-DN25-21	弹簧座	1	1Cr18Ni9Ti			
23		温度感应器	1				
22	ZZYP-16B-DN25-20	外套	1	HT25			
21	ZZYP-16B-DN25-19	拉手	4	1Cr18Ni9Ti			
20	ZZYP-16B-DN25-18	小弹簧	1	60Si2MnA			
19	ZZYP-16B-DN25-17	波纹管套	1	HT25			
18		波纹管	1				
17	ZZYP-16B-DN25-16	法兰盘	8	HT25			
16	ZZYP-16B-DN25-15	小弹簧座	1	1Cr18Ni9Ti			
15	ZZYP-16B-DN25-14	大弹簧	2	60Si2MnA			
14	ZZYP-16B-DN25-13	下弹簧座	1	1Cr18Ni9Ti			
13	ZZYP-16B-DN25-12	调压手轮	1	1Cr18Ni9Ti			
12	ZZYP-16B-DN25-11	调节螺母	1	QA19-4			
11	ZZYP-16B-DN25-10	推杆	1	2Cr13			
10	ZZYP-16B-DN25-09	上支架	1	HT25			
9	ZZYP-16B-DN25-08	圆螺母	2	HT25			
8	ZZYP-16B-DN25-07	填料压紧螺母	1	1Cr18Ni9Ti			
7	ZZYP-16B-DN25-06	填料上垫	1	1Cr18Ni9Ti			
6		填料	5	聚四氟乙烯			
5	ZZYP-16B-DN25-05	下支架	1	HT25			
4	ZZYP-16B-DN25-04	导向套	1	1Cr18Ni9Ti			
3	ZZYP-16B-DN25-03	阀芯	1	1Cr18Ni9Ti			
2	ZZYP-16B-DN25-02	阀座	1	1Cr18Ni9Ti			
1	ZZYP-16B-DN25-01	阀体	1	HT25			

序号	代号	名称	数量	材料	单件数量	总计	备注
ZZYP DN150							
标记	处数	分区	更改文件号	签名	日期		
设计	张尧敏		标准化	李宝华	2004.5.6		
校对			审定				
审核							
工艺			批准				